


**Implementation reporting of
PARCOM Recommendation 91/4
Belgian Implementation Report**



**OSPAR Commission
2007**

The Convention for the Protection of the Marine Environment of the North-East Atlantic (the “OSPAR Convention”) was opened for signature at the Ministerial Meeting of the former Oslo and Paris Commissions in Paris on 22 September 1992. The Convention entered into force on 25 March 1998. It has been ratified by Belgium, Denmark, Finland, France, Germany, Iceland, Ireland, Luxembourg, Netherlands, Norway, Portugal, Sweden, Switzerland and the United Kingdom and approved by the European Community and Spain.

La Convention pour la protection du milieu marin de l'Atlantique du Nord-Est, dite Convention OSPAR, a été ouverte à la signature à la réunion ministérielle des anciennes Commissions d'Oslo et de Paris, à Paris le 22 septembre 1992. La Convention est entrée en vigueur le 25 mars 1998. La Convention a été ratifiée par l'Allemagne, la Belgique, le Danemark, la Finlande, la France, l'Irlande, l'Islande, le Luxembourg, la Norvège, les Pays-Bas, le Portugal, le Royaume-Uni de Grande Bretagne et d'Irlande du Nord, la Suède et la Suisse et approuvée par la Communauté européenne et l'Espagne.

© OSPAR Commission, 2007. Permission may be granted by the publishers for the report to be wholly or partly reproduced in publications provided that the source of the extract is clearly indicated.

© Commission OSPAR, 2007. La reproduction de tout ou partie de ce rapport dans une publication peut être autorisée par l'Editeur, sous réserve que l'origine de l'extrait soit clairement mentionnée.

ISBN: 978-1-905859-80-1
Publication Number: 341/2007

contents

1	Introduction.....	4
2	General information.....	4
	2.1 Implementation of BAT/BET in Belgian legislation and regulation.....	4
	2.2 Basis for national legislation/regulation	4
	2.3 Dose constraints/limits for nuclear installations.....	5
	2.4 Discharge limits	5
	2.5 Environmental norms and standards.....	6
	2.6 Monitoring programmes of discharges and environmental concentrations of radionuclides.....	6
	2.7 National authority responsible for supervision of discharges	7
	2.8 Nature of inspection and surveillance programmes	7
	2.9 Reporting	7
3	Nuclear Power Plants (NPP)	8
	3.1 Sources of liquid effluent.....	8
	3.2 Liquid effluent treatment.....	8
	3.3 Nuclide libraries.....	8
	3.4 Environmental impact.....	8
	3.5 Trends in discharge over the 1998-2005 period and summary evaluation (see annex 3)	8
	3.6 Atmospheric wastes:	10
	3.6.1 Doel:.....	10
	3.6.2 Tihange:	10
	3.7 Liquid wastes:.....	11
	3.7.1 Doel:.....	11
	3.7.2 Tihange:	12
	3.8 Other relevant information:.....	13
4.	Other nuclear sites	13
	4.1 Sources of liquid effluent.....	14
	4.2 Liquid effluent treatment.....	14
	4.3 Nuclide libraries.....	14
	4.4 Environmental Impact.....	14
	4.5 Trends in discharge over the 1998-2005 period and summary evaluation (see annex 3)	14
	4.6 Atmospheric waste	15
	4.7 Liquid waste	15
	Annex 1: NPPs	16
	Annex 2: Other nuclear sites (BP).....	19
	Annex 3: Trend line figures.....	21

1 Introduction

At its 2006 meeting in Knokke, Belgium, the OSPAR Radioactive Substances Committee established, on a trial basis, revised "Guidelines for the submission of information on the assessment of the application of Best Available Technology (BAT) in nuclear facilities". In this report the requested information for Belgian nuclear installations is given. The report covers the eight-year period 1998-2005 inclusive.

The first section gives general information regarding national legislation, dose limits, discharge limits, ... The next sections give site specific information about each of the nuclear installations in Belgium.

2 General information

2.1 Implementation of BAT/BET in Belgian legislation and regulation

The first law concerning protection of the population from ionising radiation dated from 29 March 1958. The legislation with respect to radiological protection was based on the Royal Decree of 28 February 1963. After some modifications by the Royal Decrees of 17 May 1966, 22 May 1967, 23 December 1970, 23 May 1972, 24 May 1977, 12 March 1984, 21 August 1985 the legislation was thoroughly adapted by the Royal Decrees of 16 January and 11 February 1987 when the ICRP-26 and 30 (regarding the methodology for calculation internal radiation dose) were taken into account. Other modifications were made by the Royal Decrees of 12 February and 6 September 1991, 17 June 1992, 7 September 1993, 2 October 1997 and 3 May 1999.

The Federal Agency for Nuclear Control (FANC) was established by law of 15 April 1994 and according to its position it has a great independency, necessary to take up his responsibility to the society in an impartial way. It is lead by a board of directors and the daily management is observed by a General-Director.

A new legislation was created by the Royal Decree of 20 July 2001 (*General Regulations for the Protection of the population, workers and the environment against the dangers of Ionising Radiation - GRPIR*), which was necessary to harmonise the Belgian legislation with the European Directives (that take into account some recommendations of the ICRP-60). This Royal Decree attributes to the FANC the objectives of "protection of the population, workers and the environment against the dangers of ionising radiation" that consist to:

- propose, apply and improve law and regulations;
- control human (and non human) activities responsible for exposure of man to radioactivity;
- ensure the surveillance of radioactivity on the territory (TELERAD automatic network - Radiological Surveillance Monitoring programme);
- co-operation to nuclear emergency plans;
- distribute neutral and objective information.

2.2 Basis for national legislation/regulation

The Belgian policy is based on EC Directives, on international conventions and on recommendations of appropriate international bodies like the International Commission on Radiological Protection (ICRP) and the International Atomic Energy Agency (IAEA). The major principles in these regulations are:

- justification of exposure: exposure to radiation is only allowed if the advantage is larger then the possible risk and damage of the exposure;
- optimisation: known as the ALARA-principle (As Low As Reasonably Achievable), exposure has to be as low as possible, taking social and economic factors into account;
- dose limits: exposure of individuals as result of the combination of different exposures, has to be subject to limits to prevent unacceptable risks.

2.3 Dose constraints/limits for nuclear installations

The limits, which are given by the Belgian regulation *General Regulations for the Protection of the population, workers and the environment against the dangers of Ionising Radiation (GRPIR)*, are the following.

Dose	Public art. 20.1.4	Workers art. 20.1.3	apprentices and students	
			≥ 18 years art. 20.1.5	16 ≤ <18 years art. 20.1.5
Effective (whole body)	1 mSv/a	20 mSv/a *	20 mSv/a *	6 mSv/a
Equivalent for any individual organ or tissue	-	500 mSv/a *	500 mSv/a *	-
Equivalent for lens of the eye	15 mSv/a	150 mSv/a *	150 mSv/a *	50 mSv/a
Equivalent for skin **	50 mSv/a	500 mSv/a *	500 mSv/a *	150 mSv/a
Equivalent for hands, arms, feet and ankles	-	500 mSv/a *	500 mSv/a *	150 mSv/a

* for 12 consecutive months.

** average dose for each area of 1 cm² of skin

Remark: the above limits do not take into account medical exposure

Nuclear installations apply for their workers a dose constraint of 10 mSv/a.

2.4 Discharge limits

The annual limits for discharges and emissions are specified for a nuclear facility in such a way that the resulting doses to the population shall not exceed 1 mSv per year for all pathways combined (art. 20 of the Royal Decree of July 20th 2001).

The Royal Decree introduces also a notion of dose constraint (optimisation principle-ALARA): the discharge limits have to be based on a fraction of the public annual limit of 1 mSv. Dose constraints are now in discussion in the FANC: the following table shows the dose constraint proposed by and for the nuclear sites.

	Dose constraint (mSv/a)			Evaluation of real committed dose (average over the last 10 years) (mSv/a)			Reduction Yes / No
	Atmospheric discharge	Liquid discharges	Total	Atmospheric discharge	Liquid discharges	Total**	
Belgoprocess (Site of Mol)	0.3	0.2	0.5	60 10 ⁻⁶	625 10 ⁻⁶	685 10 ⁻⁶	Y
NPP Tihange	0.19	0.08	0.21	47 10 ⁻³	2.5 10 ⁻³	49 10 ⁻³	N
NPP Doel	0.18	0.23*	0.37	18 10 ⁻³	2.3 10 ⁻³	19 10 ⁻³	N

* take into account a specific critical group

** maximum dose does not necessarily correspond to the sum of doses due to atmospheric or liquid releases: the critical individual, even localised at the same place, is not always in the same age category

The model used to estimate the radiation exposure for a critical group caused by radioactive effluents of nuclear power plants was based on the NUclear REgulatory Guide (NUREG) 1.109 rev.1, USNRC. Some conservative adaptations have been made by taking into account:

- Dose conversion factors (RD of July 20th 2001) based on the ICRP 72;
- 6 classes of age (RD of July 20th 2001) : $\leq 1y$, 1-2y, 2-7y, 7-12y, 12-17y and $> 17y$;
- Eventual adaptation of some parameters (e.g. consumption habit,...).

The dose is calculated at the most unfavourable receiving points, taking into account the relevant exposure pathways and living habits, e.g. the consumption rates of different foodstuffs. On the basis of these assumptions and parameters used in the models, the radiation exposure to individuals cannot be underestimated.

2.5 Environmental norms and standards

The art. 34 of the RD of July 20th 2001 defines that liquid discharges in surface waters or sewer canalisations are forbidden when concentration in radionuclides, expressed in Bq/litre, exceeds one thousandth of the annual limit of intake by ingestion for an adult (annexe III D of the RD).

2.6 Monitoring programmes of discharges and environmental concentrations of radionuclides

Under the Royal Decree, the Federal Agency for Nuclear Control (FANC) is charged in particular with *monitoring the radioactivity of the territory and the doses received by the population* (Article 70) as well as organising the *monitoring of the population as a whole* (Article 71). It should also be noted that the Franco-Belgian co-operation agreement of September 8th 1998, relates to the Chooz nuclear power station situated on the Meuse in France close to the border with Belgium. This agreement ensures the full monitoring on Belgian territory of all radioactivity transfers around the nuclear site as well as the periodic exchange of results between states.

Between 2002 and 2004, the Agency reviewed its entire sampling and measurement programme in order to completely harmonise it with international requirements. The 1998 European Directive on drinking water had imposed:

- stronger controls, with new requirements in terms of control;
- the reporting of radiological surveillance data to the European Commission resulting from the application of Article 36 of the EURATOM treaty.

Finally, the OSPAR Convention (OSlo-PARis Convention, 1998 – ratified by Belgium) on the protection of the marine environment of the North Sea and North-East Atlantic makes the development of monitoring and research programmes concerning the impact of radioactive discharges on the marine environment mandatory.

The programme for the radiological monitoring of the territory currently relies on more than 4,000 samples annually, which are subjected to almost 27,000 alpha, beta and gamma radioactivity analyses. This radiological monitoring programme includes radioactivity measurements carried out in:

- the Meuse and Sambre basins;
- the Scheldt and Nete basins;
- the marine zone;
- a reference zone (Brussels Capital region).

For the major parts of the biosphere (air, soil, water and biocenosis) as well as in the main constituents of the food chain, supplemented by the follow-up of the atmospheric and liquid discharges of the main nuclear sites and through dose rate measurements around these facilities.


2.7 National authority responsible for supervision of discharges

All licensing and supervision activities concerning construction and operation of nuclear facilities is carried out by the regulatory authority of the federal state (FANC) with the co-operation of authorized inspection and controlling bodies. This is also the case for authorisation of radioactive discharges to the environment. FANC is under the authority of the Ministry of Interior.

2.8 Nature of inspection and surveillance programmes

The nuclear installations are inspected several times each year by the federal authorities (FANC and authorised inspection and controlling bodies). The environmental monitoring programme is undertaken by special authorised laboratories under the co-ordination and the responsibility of the federal authority (FANC). Laboratories undertake analyses in accordance with internal Quality Control procedures also involving regular calibration of detectors and yearly comparison exercises. Therefore, the quality of environmental and discharge sample measurements, and the assessment of impact of discharges and emissions on members of the general public, is based on a independent national system of governmental bodies and experts.

The TELERAD network - automatic remote radioactivity measuring network in Belgium - comprises 212 stations, which constantly measure the radioactivity of the air and river waters. The stations are distributed throughout the entire country, around the Tihange, Doel, Mol, Fleurus and Chooz nuclear installations, as well as in the urban areas close to these installations. These stations are linked to a centralised system that is automatically alerted when detecting any abnormal rise in radioactivity levels.



2.9 Reporting

The results of discharge measurements performed by operators are reported monthly to the federal authority (FANC) and are also available through annual reports.

Belgium reports annually on the FANC website all the results obtained from the radiological surveillance programme of the territory (including TELERAD, foodchain, nuclear sites discharges, ..).

Belgium reports discharge data from nuclear installations annually to EURATOM (art. 35&36 of the treaty) and to the OSPAR secretariat.

Belgium also reports hourly the dose rate data from the TELERAD network to the European Commission (EURDEP).

3 Nuclear Power Plants (NPP)

Nuclear power currently accounts for about 56% of Belgian's electric energy production. The nuclear power stations are located near Doel and Tihange. There are 7 operational pressurised water power reactors.

Discharge data are given for reactor sites. The activity concentrations of radionuclides in non-human biota of river water are so low that it is generally not possible to detect them.

Information to be submitted in accordance with the BAT Guidelines is given in Annex 1 referring to nuclear power plants for the period between 1998 and 2005.

For each installation, the information as defined in BAT Guidelines is given in tabular form:

- Name of facility
- Type of facility
- Date commissioned
- Location
- Installed electrical generation capacity
- Electricity generation
- Shut-down year
- Annual emissions and discharges, absolute and normalised according to actual output as compared to the UNSCEAR ranges
- Individual dose as compared to the national dose limits
- Waste treatment

The determination of individual dose covers all radionuclides discharged to the environment.

3.1 Sources of liquid effluent

The main sources of radioactive liquid effluent are reactor operations and small leaks from the reactor itself, associated plant, laundry and general cleaning processes. The principal radionuclides arising in liquid wastes are tritium and, to a much lesser degree, activation and fission products. See Annex 1.

3.2 Liquid effluent treatment

See 3.7.

3.3 Nuclide libraries

The radionuclides to be monitored are stipulated in the "licence to operate" of the NPP reactors under the responsibility of the federal authority (FANC).

3.4 Environmental impact

The environmental surveillance programme in the vicinity of nuclear power stations is performed by the FANC radiological monitoring programme. The analyses of environmental samples (sediment & water in rivers and north-sea, fauna & flora in freshwater and marine water, soil, air, rain, milk, foodchain, drinking water) show that there are no detectable α - and β -activity concentrations (excluding tritium) referring to radioactive discharges from NPP. Tritium discharges from pressurised water reactors can increase the tritium concentrations in surface water of rivers by 10 to 30 Bq/l (e.g. river Meuse).

3.5 Trends in discharge over the 1998-2005 period and summary evaluation (see annex 3)

Reactors have been operating steadily throughout this period, so liquid discharges have been fairly constant. For tritium, the range for normalised discharges from the stations is 9.9 to 22.4 TBq/GWa (average value 13.8 TBq/GWa for Doel and 15.4 TBq/GWa for Tihange) with no discernible trend;

for beta/gamma emitters excluding tritium, the range is 2.8 – 20.7 GBq/GWa (mean value 8.2 GBq/GWa with clear decreasing tendency for Doel and 14.6 GBq/GW with no discernible trend for Tihange).

Comparisons with UNSCEAR ranges show that:

- Tritium discharges for both NPP's are **near the lower end limit** of the range;
- Non-tritium discharges into water are always **below** the level of the range for Doel and **near the lower end limit** of the range for Tihange.

For both nuclear installations, calculations made for liquid discharges under conservative assumptions show that the maximum effective doses to the population in the vicinity of the NPP's are well below the national limits of 1 mSv/a (maximum limit including all atmospheric and liquid contributions): 0.23% for Doel and 0.24% for Tihange for liquid discharges.


For both nuclear installations, calculations made for atmospheric discharges under conservative assumptions show that the maximum effective doses to the population in the vicinity of the NPP's are well below the national limits : 1.80% of the annual maximum limit of 1 mSv/a for Doel and 2.25% for Tihange.

The low levels of radioactivity discharges and emissions from all nuclear power stations and low levels of radiation exposure in general show that the best available technology is being applied in Belgium.

Another interesting point to note concerns the quantity of liquid and solid waste generated by nuclear power stations (chart below). While the total production of electricity has remained more or less constant at around 45 TWh in recent years, the quantity of radioactivity discharged - excluding Tritium - in the liquid effluents has sharply declined and has stabilised at around 44 GBq in 2005 (15.1 GBq/GWa in 2005). This observation is even more amplified when the volume of solid waste generated per TWh produced and removed for treatment and storage by the National Organisation for Radioactive Waste and Enriched Fissile Materials (ONDRAF - NIRAS) is considered: current volumes tend to be around 3.5 m³/TWh.

This shows also the efforts made by Belgian NPP's to reconcile the objectives of optimising industrial operations, notably in reducing the volumes of waste produced and the related costs while, on the other hand, "reducing" the discharge of effluents as far as possible. These elements of assessment clearly demonstrate the application of the BAT concept with regard to liquid and solid waste.

Production of the Belgian nuclear sites (Doel and Tihange NPP)



3.6 Atmospheric wastes:

3.6.1 Doel:

Origin: reactor building, space between the reactor building itself and the second containment, fuel building, nuclear auxiliaries building.

Treatment: all gas releases from the reactor buildings themselves and from the inter-space between both containments and of some WAB controlled areas are sent to storage tanks. All gas from other sources (ventilation, non-condensable gas, machinery rooms, demineralisation building, other WAB building areas, ...) are continuously released through filters and monitored.

Waste management: releases are generated from Doel 1&2 reactors, Doel 3 reactor, Doel 4 reactor and some of the WAB controlled areas (water and waste treatment building). Once the radioactivity of a full storage tank has sufficiently decreased, effluents are released through the chimney (presence of filters and continuous monitoring). All gas from other sources (ventilation, non-condensable gas, machinery rooms, demineralisation building, other WAB building areas, ...) are continuously released through filters and monitored. When “action” levels are exceeded, gas releases are by-passed through HEPA filters (High Efficiency Particulate Air filters). Filters and active carbon cartridges - trapping iodine - are analysed weekly (determination of iodine concentration and gamma spectrometry). Using monthly aliquots, beta and alpha measurements are conducted on filters; ⁸⁵Kr is determined on gas; tritium is determined on condensed gas.

3.6.2 Tihange:

Origin: 1) space between the reactor building itself and the second containment (“inter-space”), fuel building (spent-fuel pool), nuclear auxiliaries building (ventilation, machinery rooms, laundry building, demineralisation building, decontamination building, ...); 2) Gaseous effluents from hydrogenous circuits (primary circuit, chemical and volumetric conditioning circuits), atmosphere of the reactor building itself (70,000 m³).

Treatment: all gas releases from 1) are continuously monitored, can be filtered and released (at a rate of 150,000 to 250,000 m³/h). Gas releases from 2) are sent to storage / decay tanks.

Waste management: releases from 2) for each reactor (Tihange 1, Tihange 2 & Tihange 3) are sent to primary storage tanks. Once the radioactivity of a full storage tank has sufficiently

decreased, effluents are released through the chimney at a maximum rate of 75 m³/h (presence of filters and continuous monitoring). All gas from 1) is continuously released and monitored. When “action” levels are exceeded, gas releases are by-passed through HEPA filters (High Efficiency Particulate Air filters) and active carbon filters. Filters and active carbon cartridges - trapping iodine (excepted for laundry and decontamination buildings) - are analysed weekly (determination of iodine concentration and gamma spectrometry). Using monthly aliquots, beta and alpha measurements are conducted on filters; ⁸⁵Kr is determined on gas; tritium is determined by calculation taking into account flow rate and concentration.

3.7 Liquid wastes:

3.7.1 Doel:



Origin: there are 4 reactors and in each reactor building there are 3 kinds of liquid wastes: recyclable waste waters (leakages from primary circuit) from the controlled areas called “primary waters”, non-recyclable waste waters (floor, laundry, lavatory, chemical, “demineralisation effluents” from steam generators) from the controlled areas and non-recyclable waste waters (floor, regeneration effluents from machinery, ...) coming from other non-controlled areas.

Treatment: ion-exchange procedures, filtration and evaporation of waste waters (in evaporators, Tritium from the distillate is condensed and released as a liquid fraction). The concentrate phase is conditioned in the NPP itself as solid concrete waste.

Waste management: primary waters as non-recyclable waters coming from controlled areas are sent to the WAB (water and waste treatment building). Waters coming from other non-controlled areas are directly sent to the ELK (unique release collector to the Scheldt river after dilution) after control of the radioactivity concentration. In WAB, effluents are kept in a tank. After treatment, effluents are sent to a management building (L building) where they are diluted by secondary waters at a flow rate of 150 m³/h. Diluted waters are then sent to the ELK building. There is a late dilution with tertiary cooling waters (at a flow rate of 150,000 m³/h). Then waters are released to the Scheldt river if the radioactivity is below 0.1 MBq/m³.

3.7.2 Tihange:



Origin: there are 3 reactors and for each reactor building there are 2 main categories of liquid wastes: recyclable waste waters (primary waters or hydrogenous waters) and non-recyclable waste waters (floor, laundry, lavatory, chemical such as labs decontamination component cooling systems, “demineralisation effluents” from steam generators, regeneration effluents from machinery, ...).

Treatment: ion-exchange procedures, filtration and evaporation of waste waters (in evaporators, Tritium from the distillate is condensed and released as a liquid fraction). The concentrate phase is conditioned in the NPP itself as solid concrete waste.

Waste management: recyclable effluents are collected in their respective units (Tihange 1, 2 or 3) and then pumped to unit 2 where they are filtered (1 or 5 μm filters), demineralised (anionic, cationic and mixed bed resins), degassed (fission gas) and evaporated. The distillate (bore) is recovered, the filtrate (containing tritium) is sent to the RAR tank (storage tank before release to river) of the originating unit. The residue (containing residual non recovered bore) is eliminated as solid waste (cementation).

Non-recyclable effluents are identically collected in their respective units and are also pumped to unit 2. If the radioactivity is low, treatment will be conducted by filtration. If the radioactivity is higher, most of the effluents will be treated by evaporation or through filters and ion exchange resins. The distillate (evaporation) and/or filtrate (filtration) are treated as a low level activity effluents, analysed and repumped to the RAR tank (storage tank before release to river) of the originating unit. In either case, solid residues are treated as solid waste according ONDRAF procedures.


All effluents from the RAR, after second analyses, are pumped to their own end collector. There, they are mixed with and diluted by waters from machineries and their respective cooling tower before being released to the Meuse river.

3.8 Other relevant information:

All liquid waste management and treatments are audited according to EMAS (Eco-Management and Audit Scheme) and ISO 14001 certifications.

For Doel NPP e.g., for the last six years, following factors have influenced the reduction of radioactive liquid releases:

- more liquid wastes are evaporated to solid wastes instead of being released in the Scheldt river;
- replacement of the steam generators of reactor 2 allows to recover the “blow-down” waters which induced a significant decrease of liquid releases.



4. Other nuclear sites

There are two other nuclear sites in Belgium: the Fleurus site (IRE-National Institute of Radioelements) in Wallonia and the Mol-Dessel site (the Nuclear Research Centre SCK•CEN / Belgoprocess sites 1&2 (BP) / Belgonucléaire / FBFC International - Franco-Belge de Fabrication de Combustibles International / IRMM – Institute for Reference Materials and Measurements) in Flanders. The facilities at these sites carry out scientific, technical and commercial programmes in the nuclear field.

For the IRE site there are no liquid discharges: all liquid wastes are sent to the Mol-Dessel site (Belgoprocess site 2) for treatment. All the liquid discharges produced by the Mol-Dessel site are also managed by the Belgoprocess facilities.

For Belgoprocess site 2 the information, as defined in BAT Guidelines, is given in tabular form (annex 2):

- Name of facility
- Type of facility
- Location
- Annual emissions and discharges
- Individual dose as compared to the national dose limits
- Waste treatment

The determination of individual doses covers all radionuclides discharged to the environment.

Belgoprocess site 1



4.1 Sources of liquid effluent

The radioactive liquid effluents are generated by the waste treatment unit of Belgoprocess 2. Liquid discharges are operated in the Molve Nete river with a limit set at 166 GBq/month or 1.99 TBq/a according to the following weighting formulae:

$2,5[\square \text{ total}] + 0,4[{}^{90}\text{Sr}-{}^{90}\text{Y}] + 0,025[{}^3\text{H}] + [{}^{60}\text{Co}] + 1,5[{}^{134}\text{Cs}] + 1,5[{}^{137}\text{Cs}] + 0,1[\square] \leq 166 \text{ GBq/month}$
in the river Molve Nete.

with $[\square] = [\square \text{ total}] - ([{}^{90}\text{Sr}-{}^{90}\text{Y}] + [{}^{60}\text{Co}] + [{}^{134}\text{Cs}] + [{}^{137}\text{Cs}])$

The discharges from the site into the Molve Nete adequately comply with the limit set, even though they are not negligible. The principal radionuclides arising in liquid waste are tritium and, to a much lesser degree, activation and fission products. See Annex 2.

4.2 Liquid effluent treatment

See 4.7.

4.3 Nuclide libraries

The radionuclides to be monitored are stipulated in the licences of the nuclear sites under the responsibility of the FANC federal authority.

4.4 Environmental Impact

The environmental programme in the vicinity of the nuclear sites is performed by the FANC radiological monitoring programme. The analyses of environmental samples (sediment & water in rivers and north-sea, fauna & flora in freshwater and marine water, soil, air, rain, milk, foodchain, drinking water) show that there are no detectable α - and β -activity concentrations (excluding tritium) related to radioactive discharges from the sites.

4.5 Trends in discharge over the 1998-2005 period and summary evaluation (see annex 3)

The installations have been operating more or less steadily throughout this period, so liquid discharges have been fairly constant. For tritium, we notice a small increase for discharges during the period 2003-2005 (2.01 TBq to 2.37 TBq). For beta emitters excluding tritium, releases decrease exponentially from 2000 to 2005 (2.4 GBq to 0.2 GBq). For alpha emitters, releases have increased to a maximum of 98.7 MBq in 2001 and then decreased exponentially to 41.5 MBq in 2005.

4.6 Atmospheric waste


Origin: at Belgoprocess, gaseous wastes can be produced by burning solid and liquid wastes, by the gaseous and liquid waste treatments, by building ventilations, ... The other nuclear installations, mentioned in §53, also produce atmospheric wastes but will not be further discussed in this report.

Treatment: filtration by HEPA filters before releases in the chimneys.

Waste management: after filtration, releases are continuously monitored and sampled.

4.7 Liquid waste

Belgoprocess site 2 (liquid waste treatment and releases)



Origin: liquid wastes treated by BP are mainly produced by SCK•CEN and Belgoprocess installations. Beside that, there are also effluents coming from Doel and Tihange NPP's, Belgonuclaire, FBFC International, IRE, IRMM (production of calibrated/reference sources, cyclotron) sites and finally hospitals and research centres (universities, ...).

Treatment: there are different kinds of effluents:

- *suspicious* effluents where activity is $< 400 \text{ kBq/m}^3$ for beta/gamma emitters and $< 40 \text{ kBq/m}^3$ for alpha emitters;
- *contaminated* effluents where activity is $< 400 \text{ MBq/m}^3$ for beta/gamma emitters and $< 800 \text{ kBq/m}^3$ for alpha emitters;
- *high radioactive* effluents where activity is $< 40 \text{ GBq/m}^3$ for beta/gamma emitters and $< 80 \text{ MBq/m}^3$ for alpha emitters.

Effluents are treated by sedimentation in decantation tank, the particulate phase is sent to a storage tank where other sedimentation/decantation processes occur. Depending on the radioactivity levels, the liquid phase is evaporated by BP.

Waste management: residues or solid phases are conditioned by BP cementation and bitumisation before storage. High solid wastes are vitrified and stored. Before liquid effluents are released into the Molse Nete river, the following limits have to be respected: concentration $< 37 \text{ MBq/m}^3$ and $< 166 \text{ GBq/month}$ or 1.99 TBq/a according to the weighting formulae described in 4.1.

Annex 1: NPPs

1. Site Characteristics

Name of facility	NPP Doel
Type of facility	PWR
Date commissioned	1975-1975-1982-1985
date of shut-down	2015-2015-2022-2025
Location	Belgium (Doel)
Receiving water	Scheldt

Installed capacity	1998	1999	2000	2001	2002	2003	2004	2005
MW[e]	2776	2776	2776	2776	2776	2776	2817	2817

Electricity generation (net)	1998	1999	2000	2001	2002	2003	2004	2005
GWh		~21800			21801	21780	21404	21886

2. Discharge and emission data annual liquid discharges, Bq/a

Radionuclide (TBq/a)	1998	1999	2000	2001	2002	2003	2004	2005
Co-58	2.91E-03	9.32E-03	5.15E-03	8.43E-04	2.29E-03	5.09E-04	3.85E-04	0.00E+00
Co-60	5.30E-04	2.43E-03	1.37E-03	9.50E-04	1.21E-03	1.05E-04	2.17E-04	3.09E-04
Zn-65	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Sr-90	2.20E-05	2.13E-04	1.33E-04	2.31E-05	9.20E-06	1.00E-06	0.00E+00	3.70E-06
Zr/Nb-95	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.59E-05
Ru-106	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ag-110m	1.80E-04	4.30E-05	5.18E-04	6.32E-05	3.68E-05	5.23E-04	1.31E-03	2.76E-04
Sb-125	1.94E-03	2.25E-03	2.13E-03	2.11E-03	1.98E-03	2.54E-03	1.14E-03	2.16E-03
Cs-134	3.08E-03	3.54E-03	6.57E-04	0.00E+00	2.50E-04	6.00E-05	5.80E-05	3.67E-05
Cs-137	6.67E-03	9.42E-03	3.49E-03	2.73E-03	3.62E-03	3.49E-03	1.40E-03	5.81E-04
Ce-144	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Total-Beta*	1.60E-02	2.78E-02	1.50E-02	6.70E-03	1.17E-02	8.41E-03	5.22E-03	4.52E-03
Total activity excluding H-3	3.13E-02	5.50E-02	2.84E-02	1.34E-02	2.11E-02	1.56E-02	9.73E-03	7.92E-03
H-3	4.71E+01	4.84E+01	3.09E+01	3.80E+01	2.75E+01	3.43E+01	4.21E+01	3.99E+01
Total-Alpha	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.20E-06	0.00E+00	0.00E+00

	1998	1999	2000	2001	2002	2003	2004	2005
Total activity excluding H-3	3.13E-02	5.50E-02	2.84E-02	1.34E-02	2.11E-02	1.56E-02	9.73E-03	7.92E-03
Annual limit (TBq/a)	1.50E+00	1.50E+00	1.50E+00	1.50E+00	1.50E+00	1.50E+00	1.50E+00	1.50E+00
% of annual limit	2.1	3.7	1.9	0.9	1.4	1.0	0.6	0.5
Normalised to capacity (GBq/GWa)	11.3	19.8	10.2	4.8	7.6	5.6	3.5	2.8
UNSCEAR ranges (GBq/GWa)	14 - 140							
H-3	4.71E+01	4.84E+01	3.09E+01	3.80E+01	2.75E+01	3.43E+01	4.21E+01	3.99E+01
Annual limit (TBq/a)	1.04E+02	1.04E+02	1.04E+02	1.04E+02	1.04E+02	1.04E+02	1.04E+02	1.04E+02
% of annual limit	45.5	46.7	29.8	36.7	26.5	33.1	40.6	38.5
Normalised to capacity (TBq/GWa)	17.0	17.4	11.1	13.7	9.9	12.4	14.9	14.2
UNSCEAR ranges (TBq/GWa)	7,9 - 80							

3. Annual aerial emissions (Bq/a)

	1998	1999	2000	2001	2002	2003	2004	2005
H-3 (TBq/a)	0.052	5.665	0.017	0.326	1.026	0.710	0.030	0.476
Normalised to capacity (TBq/GWa)	0.03	2.83	0.01	0.16	0.51	0.35	0.01	0.24

C-14 is not measured and estimated to 5,55E+02 GBq/a (according to literature** that mentions 5 Ci/a (18.5 GBq/a) for 1000 MWe installed)

4. Radiation doses to the public

Effective Dose (mSv/a)***	1992 to 2001	2002	2003	2004	2005
Water pathway	0.0023	0.0013	0.0010	0.0007	0.0006
% of dose limit (1 mSv/a)	0.23	0.13	0.1	0.07	0.06
Air pathway	0.0087	0.0087	0.0086	0.0085	0.0086
% of dose limit (1 mSv/a)	0.87	0.87	0.86	0.85	0.86

* Value of "other radionuclides" (= total Beta-Gamma) reported as mentioned in the 'instructions for the reporting format for liquid discharges of radioactive substances from nuclear installations' (point 8)

** Investigations into the emission of C-14 compounds from nuclear facilities, J. Schwibach, H. Riedel und J. Bretschneider, november 1978, Commission of the European Communities

*** given for an adult. Calculated by NUREG 1.109, DCF ICRP-72

1. Site Characteristics

Name of facility	NPP Tihange
Type of facility	PWR
Date commissioned	1975-1982-1985
date of shut-down	2015-2022-2025
Location	Belgium (Tihange)
Receiving water	Meuse

Installed capacity	1998	1999	2000	2001	2002	2003	2004	2005
MW[e]	2973	2973	2973	2973	2985	2985	2985	2985

Electricity generation (net)	1998	1999	2000	2001	2002	2003	2004	2005
GWh		~23000			23186	23141	23495	23183

2. Discharge and emission data annual liquid discharges, Bq/a

Radionuclide (TBq/a)	1998	1999	2000	2001	2002	2003	2004	2005
Co-58	8.46E-03	6.21E-03	8.34E-03	2.06E-02	1.46E-02	1.37E-02	1.07E-02	8.40E-03
Co-60	4.60E-03	3.84E-03	3.78E-03	5.30E-03	5.32E-03	5.07E-03	8.33E-03	5.22E-03
Zn-65	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Sr-90	2.10E-05	5.75E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zr/Nb-95	1.59E-04	2.20E-04	2.35E-04	1.02E-03	6.93E-05	3.00E-04	5.28E-04	2.62E-04
Ru-106	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.25E-04
Ag-110m	1.87E-03	3.59E-04	8.40E-04	3.57E-04	8.27E-04	1.48E-03	1.44E-03	7.16E-04
Sb-125	1.58E-03	4.02E-04	2.70E-04	4.47E-04	1.02E-03	8.48E-04	1.95E-03	8.43E-04
Cs-134	2.47E-04	9.05E-05	5.10E-05	9.62E-05	2.99E-04	1.17E-03	2.08E-03	7.89E-04
Cs-137	1.05E-03	2.88E-04	3.50E-04	4.22E-04	5.36E-04	1.15E-03	2.10E-03	1.27E-03
Ce-144	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.50E-06	9.00E-06
Total-Beta*	2.00E-02	1.27E-02	1.57E-02	3.32E-02	2.66E-02	2.66E-02	3.13E-02	1.90E-02
Total activity excluding H-3	3.80E-02	2.41E-02	2.96E-02	6.15E-02	4.93E-02	5.03E-02	5.84E-02	3.66E-02
H-3	3.29E+01	6.66E+01	3.31E+01	4.10E+01	5.96E+01	4.35E+01	4.55E+01	4.60E+01
Total-Alpha	9.00E-07	9.00E-07	7.10E-07	1.20E-07	0.00E+00	9.10E-10	5.13E-09	2.11E-09

	1998	1999	2000	2001	2002	2003	2004	2005
Total activity excluding H-3 (TBq/a)	3.80E-02	2.41E-02	2.96E-02	6.15E-02	4.93E-02	5.03E-02	5.84E-02	3.66E-02
Annual limit (TBq/a)	8.88E-01	8.88E-01	8.88E-01	8.88E-01	8.88E-01	8.88E-01	8.88E-01	8.88E-01
% of annual limit	4.3	2.7	3.3	6.9	5.5	5.7	6.6	4.1
Normalised to capacity (GBq/GWa)	12.8	8.1	9.9	20.7	16.5	16.9	19.6	12.3
UNSCEAR ranges (GBq/GWa)	14 - 140							
H-3 (TBq/a)	3.29E+01	6.66E+01	3.31E+01	4.10E+01	5.96E+01	4.35E+01	4.55E+01	4.60E+01
Annual limit (TBq/a)	1.48E+02	1.48E+02	1.48E+02	1.48E+02	1.48E+02	1.48E+02	1.48E+02	1.48E+02
% of annual limit	22.3	45.1	22.4	27.8	40.4	29.5	30.8	31.2
Normalised to capacity (TBq/GWa)	11.1	22.4	11.1	13.8	20.0	14.6	15.2	15.4
UNSCEAR ranges (TBq/GWa)	7,9 - 80							

3. Annual aerial emissions (Bq/a)

	1998	1999	2000	2001	2002	2003	2004	2005
H-3 (TBq/a)	6.35	7.32	7.56	5.65	5.26	5.66	6.75	6.51
Normalised to capacity (TBq/GWa)	2.14	2.46	2.54	1.90	1.76	1.90	2.26	2.18

C-14 is not measured and estimated to 5,55E+02 GBq/a (according to literature** that mentions 5 Ci/a (18.5 GBq/a) for 1000 MWe installed)

4. Radiation doses to the public

Effective Dose (mSv/a)***	1992 to 2001	2002	2003	2004	2005
Water pathway	0.0024	0.0025	0.00226	0.00295	0.00213
% of dose limit (1 mSv/a)	0.24	0.25	0.226	0.295	0.213
Air pathway	0.0225	0.0224	0.0228	0.0227	0.0226
% of dose limit (1 mSv/a)	2.25	2.24	2.28	2.27	2.26

* Value of "other radionuclides" (= total Beta-Gamma) reported as mentioned in the 'instructions for the reporting format for liquid discharges of radioactive substances from nuclear installations' (point 8)

** Investigations into the emission of C-14 compounds from nuclear facilities, J. Schwibach, H. Riedel und J. Bretschneider, november 1978, Commission of the European Communities

*** given for an adult. Calculated by NUREG 1.109, DCF ICRP-72

Annex 2: Other nuclear sites (BP)

1. Site Characteristics

Name of facility	Belgoproces (BP)
Type of facility	Wastes treatment and storage centre
Location	Belgium (Mol-Dessel)
Receiving water	Molse Nete

2. Discharge and emission data annual liquid discharges, Bq/a

Year		1998	1999	2000	2001	2002
Tritium	[1] MBq	1300000	3343600	2341300	2287900	2162100
	[2] MBq	1300	3344	2341	2288	2162
Total-α	[1] MBq	33.6	21.3	80.8	98.7	83.2
	[2] MBq	168.2	106.5	404.1	493.4	416.0
Total-β	[1] MBq	2316.3	1430.0	2438.1	2110.4	1373.1
	[2] MBq	2316.3	1430.0	2438.1	2110.4	1373.1
Co 60	[1] MBq					
	[2] MBq					
Sr/Y 90	[1] MBq	178.7	149.9	108.6	111.6	63.0
	[2] MBq	1340.3	1124.3	814.5	837.0	472.5
I 131	[1] MBq	3.5	5.1	8.0	3.3	4.2
	[2] MBq	10.6	15.2	23.9	10.0	12.5
Cs 134	[1] MBq					
	[2] MBq					
Cs 137	[1] MBq					
	[2] MBq					
Ra 226	[1] MBq	0.030	0.032	0.032	0.032	0.033
	[2] MBq	8.9	9.5	9.7	9.5	9.9
GBq released	per annum [3]	1.30E+03	3.35E+03	2.34E+03	2.29E+03	2.16E+03
TBq released	per annum [4]	5.144	6.029	6.032	5.748	4.446
		[5]	[5]	[5]	[5]	[5]

Year		2003 [7]	2003 [8]	2003 [9]	2004	2005
Tritium	[1] MBq	494600	1516800	2011400	2204000	2372800
	[2] MBq	495	37920	38415	55100	59320
Total-α	[1] MBq	5.9	53.6	59.5	46.4	41.5
	[2] MBq	29.5	134.0	163.4	116.0	103.7
Total-β	[1] MBq	233.6	281.8	515.4	281.8	213.9
	[2] MBq	233.6	28.2	261.8	28.2	21.4
Co 60	[1] MBq		43.0	43.0	63.0	109.0
	[2] MBq		43.0	43.0	63.0	109.0
Sr/Y 90	[1] MBq	18.4	73.9	92.3	117.6	69.1
	[2] MBq	138.0	29.6	167.6	47.0	27.6
I 131	[1] MBq	1.7		1.7		
	[2] MBq	5.0		5.0		
Cs 134	[1] MBq		18.0	18.0	19.0	56.0
	[2] MBq		27.0	27.0	28.5	84.0
Cs 137	[1] MBq		383.0	383.0	324.0	315.0
	[2] MBq		574.5	574.5	486.0	472.5
Ra 226	[1] MBq	0.011		0.011		
	[2] MBq	3.4		3.4		
GBq released	per annum [3]	4.95E+02	1.52E+03	2.01E+03	2.20E+03	2.37E+03
GBq released	per annum [4]	0.904	38.112	39.016	55.291	59.473
		[5]	[6]	[5] + [6]	[6]	[6]

- [1] Amount of the radionuclide in MBq
 [2] Weighted Amount of the radionuclide in MBq being [1] multiplied by its weighting coefficient
 [3] Being the total amount of activity in TBq released
 [4] Being the total amount of ponderated activity in TBq released
 [5] Total Weighted Amount in TBq according former formula
 $0,001[H3] + 5[\alpha] + 1[\beta] + 7,5[Sr90] + 3[I131] + 300[Ra226]$
applicable until March 2003
 [6] Total Weighted Amount in TBq according actual formula
 $0,025[H3] + 2,5[\alpha] + 0,1[b] + 1[Co60] + 0,4[Sr/Y90] + 1,5[Cs134] + 1,5[Cs137]$
 with [b] = total beta ([β]) activity - [[Sr/Y90] + [Co60] + [Cs134] + [Cs137]]
applicable from April 2003
 [7] Activity values for the months January, February and March calculated according formula [5].
 [8] Activity values for the months April until December calculated according formula [6].
 [9] Sum of the activities [7] and [8], being the amount for the whole year 2003.

3. Radiation doses to the public

Effective Dose (mSv/a)*	1995 to 2005
Water pathway	6.25E-04
% of dose limit (1 mSv/a)	0.0625
Air pathway**	2.05E-04
% of dose limit (1 mSv/a)	0.0205









* given for an adult. Calculated by NUREG 1.109, DCF ICRP-72



** for the total site Mol-Dessel (Belgoproces, SCK•CEN, FBFC, Belgonucléaire, IRMM)

Annex 3: Trend line figures

DOEL NPP

TIHANGE NPP





BELGOPROCESS 2

